

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1004:0110 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Apollo America Inc. 25 Corporate Dr., Auburn Hills, MI 48326
Contact: John Schertel (248) 332-3900 Fax (248) 332-8807
Email: John.Schertel@apollo-fire.com

DESIGN: Models MR-600, MR-700, MR-800 series relay modules. MR-600 series employs manual override relays. All modules employ suffix C (Grey enclosure) or C/R (Red enclosure). Refer to listee's data sheet for detailed product description and operational considerations.

RATING: MR-600 series = coil voltage: 24V dc or 24 V ac
MR-700 series = coil voltage: 12 V dc or 24 V dc
MR-800 series = coil voltage: 24 V dc or 24 V ac or 120 V ac

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as relay modules for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

NOTE: 1. Formerly Air Products and Controls, Inc.

09-09-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division