McGuire's Commercial Stops and Supply Kits

- **Performance tested to meet demanding mechanical test ASME A112.18.1-2011/B125.2-11**
- **Chlorine, chloramine and high temperature resistant by using a peroxide cured purple washer, a feature unique to McGuire stops**
- **All brass stems do not crack like residential plastic stems**
- **Four commercial lines including our Convertible™ Quarter-Turn Ball Valve, traditional full turn solid brass and dual stop valves now available in all connections: sweat, IPS and compression**

www.mcguiremfg.com

McGUIRE

Stops_Supplies 2016.psd

McGuire Manufacturing Co., Inc.
60 Grandview Court
P.O. Box 746 • Cheshire, CT 06410
203-699-1801 • Fax: 203-699-1813
www.mcguiremfg.com

SAMPLE SPECIFICATION FOR LAVATORY TRIM

Note: Product component options in parentheses.

P-Trap

Lavatory and sink P-Traps shall be (1¼", 1¼" x 1½", 1½", 1½" x 2", 2") chrome plated cast brass, (adjustable, ground joint swivel, NY, sweat styles) (with, without) cleanout, with (17 gauge seamless brass adjustable wall bend, cast brass nipple, 17 gauge seamless sweat tube), cast brass slip nuts, no reducing washers. P-Trap shall be provided with (shallow, deep, bell) (steel, brass, forged brass with setscrew) flange. P-Trap to have 2" water seal and rough-in complete, adapter extensions are not allowed. P-Trap shall be certified by CSA or other recognized testing authority and marked with manufacturer's name. Part # _____

Supply Kit

Lavatory and closet supply kits shall include chrome plated all brass stops with brass stems, no plastic stems. Kits shall have (12", 15", 20") chrome plated copper risers and (shallow, deep, bell) (steel, brass, forged brass with setscrew) flange. Inlet shall be (⅜", ½") (IPS, sweat, sweat with 5" extension, compression). Outlet shall be (⅜", ½") (IPS, compression). Supply kit shall be certified by recognized testing authority, marked with manufacturer's name and comply with the SDWA (Safe Drinking Water Act) "No Lead" restrictions of ANSI NSF 61, Sec. 9. Part # _____

Grid Drain

Lavatory grid drains (offset grid drains) shall be (1¼", 1½") chrome plated cast brass strainer (with, without overflow) and brass lock nut. Drain tailpiece shall be 17 gauge seamless brass tube and a minimum of 6" long. Grid drain shall be certified by CSA or other recognized testing authority and be marked with manufacturer's name. Part # _____

ProWrap® ADA Seamless Insulator

All exposed lavatory and sink trim on wheelchair accessible fixtures shall be covered with a seamless antimicrobial vinyl insulating outer shell. Material shall be flame retardant and fungal and bacterial resistant. Insulating kits shall include covers for, drain tailpiece, all P-Trap components, and hot and cold water supplies.
Part # _____

SANIGUARD® COMPONENT HARDWARE

SANIGUARD® antimicrobial product protection inhibits the growth of common non-public health bacteria, molds and fungi that cause odors, staining and product deterioration on treated surfaces. This product is not a disinfectant and does not protect the user or others against food-borne illnesses or disease-causing bacteria, viruses or germs. Always use proper hygiene and cleaning procedures. Part # _____SAN

All McGuire Specification Sheets
are available at www.mcguiremfg.com

To request a complete McGuire Specification Manual
email customerservice@mcguiremfg.com

WARNING:
This product can expose you to chemicals including lead, which is known to the State of California to cause cancer, and birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov.

© 2018 McGuire Manufacturing Co., Inc. All rights reserved