CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7260-1508:0105 Page 1 of 1

CATEGORY: 7260 -- SMOKE DETECTION SYSTEM-BEAM TYPE

LISTEE: FIRE FIGHTING ENTERPRISES LTD9 HUNTING GATE HITCHIN, HERTFORDSHIRE,

England SG4 0TJ United Kingdom

Contact: PAUL OTTAVIO +44 (0)1462 444 740 Fax +44 (0)1462 444 789

Email: pottavio@ffeuk.com

DESIGN: Model Fireray 3000 Projected Beam Smoke Detector. Unit consist of a controller,

transmitter and receiver. Refer to listee's data sheet for detailed product description and

operational considerations.

RATING: 12 to 36 Vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as projected beam smoke detection systems for use with separately listed compatible

fire alarm control units. Authority having jurisdiction should be consulted prior to installation.

Refer to listee's Installation Instruction Manual for details.





This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: August 13, 2018 Listing Expires June 30, 2019

Authorized By: DAVID CASTILLO, Program Coordinator

Fire Engineering Division