

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1508:0103 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: FIRE FIGHTING ENTERPRISES LTD9 HUNTING GATE HITCHIN, HERTFORDSHIRE,
England SG4 0TJ United Kingdom
Contact: PAUL OTTAVIO +44 (0)1462 444 740 Fax +44 (0)1462 444 789
Email: pottavio@ffeuk.com

DESIGN: Model LLC remote test switch, projected beam detector accessory. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 10-30V

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as a remote test switch for use with Models 50RU and 100RU (CSFM Listing No. 7260-1508:102) Projected Beam Smoke Detectors. Refer to listee's Installation Instruction Manual for details.

*Rev. 06-22-2006



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **August 13, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division