

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0553:0108 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: SPACE AGE ELECTRONICS 58 Chockett Road, Sterling, MA 01564
Contact: Robert Scholl (508) 485-0966 Fax (508) 485-4740
Email: bobs@1sae.com

DESIGN: Models WP1 and WP2 Type 3R duct smoke detector enclosure. Intended for outdoor use, primarily to provide a degree of protection against rain, sleet and damage from external ice formation. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Type 3R, Outdoor Use

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, "Type 3R enclosure", may also be marked "Rainproof" and UL label.

APPROVAL: Listed as an outdoor box Type 3R enclosure for duct smoke detector.

3-01-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division